

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ ਨੰ: 1, ਬਟਾਲਾ।

ਸੇਵਾ ਵਿਖੇ

ਜਿਲ੍ਹਾ ਸਿੱਖਿਆ ਅਫਸਰ (ਸੈ.ਸਿ),  
ਗੁਰਦਾਸਪੁਰ।

ਨੰਬਰ:

ਮਿਤੀ:

ਵਿਸ਼ਾ:- ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਹਵਾਲਾ:- ਆਪ ਜੀ ਦੇ ਦਫਤਰ ਦਾ ਪਿੱਠ ਅੰਕਣ ਨੰ: ਜੀ.3/2024/4518 ਮਿਤੀ 04.03.2024

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਦੇ ਸਬੰਧ ਵਿੱਚ Guru Har Rai Intelligent Treasure School ਵਿਖੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦੀ ਪ੍ਰੋਵੀਜ਼ਨ ਤਸੱਲੀ ਬਖਸ਼ ਪਾਈ ਗਈ ਹੈ। ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦਾ ਸਰਟੀਫਿਕੇਟ ਮਿਤੀ 31.03.2025 ਤੱਕ ਇਸ ਸਰਤ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇਕਰ ਇਸ ਸਮੇਂ ਦੌਰਾਨ ਮੁੜ ਚੈਕਿੰਗ ਕਰਨ ਤੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਵਿੱਚ ਕੋਈ ਕਮੀ ਪੇਸ਼ੀ ਪਾਈ ਗਈ ਤਾਂ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਕਰਨ ਦਾ ਹੱਕ ਮਹਿਕਮੇ ਵੱਲੋਂ ਰਾਖਵਾਂ ਹੋਵੇਗਾ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ ਨੰ: 1,  
ਬਟਾਲਾ।

ਪਿੱਠ ਅੰਕਣ ਨੰ: 832

ਮਿਤੀ: 24-24

ਉਪਰੋਕਤ ਦੀ ਨਕਲ Guru Har Rai Intelligent Treasure School ਨੂੰ ਸੂਚਨਾਂ ਹਿੱਤ ਭੇਜੀ ਜਾਂਦੀ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ ਨੰ: 1,  
ਬਟਾਲਾ।

ਪਿੱਠ ਅੰਕਣ ਨੰ:

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦੀ ਨਕਲ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ: 1 ਬਟਾਲਾ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰ: 210 ਮਿਤੀ 22-03-2024 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾਂ ਹਿੱਤ ਭੇਜੀ ਜਾਂਦੀ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ ਨੰ: 1,  
ਬਟਾਲਾ।

**REGIONAL WATER TESTING LAB, AMRITSAR**

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com

To,

SDE Water Supply and Sanitation Sub Division No 1 Batala  
SDE Water Supply and Sanitation Sub Division No 1 Batala

No.: RWTLASR/2324/00892 Dated : 20/03/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 177 Dated: 15/03/2024

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 18/03/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory  
For, Regional Water Testing Lab  
Amritsar

## REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : <b>SDE Water Supply and Sanitation Sub Division No 1 Batala</b> <b>SDE Water Supply and Sanitation Sub Division No 1 Batala</b>			Customer Reference No.		No : 177 Dated : 15/03/2024	
			Sample Submitted by		Mr.Gurvinder Singh	
			Date of Sample Receipt		18/03/2024	
			Analysis Starting Date		18/03/2024	
			Analysis completion Date		19/03/2024	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLASR/2324/00892		Date of Issue :		20/03/2024
Registration no.:		RWTLASR/REG2324/08506		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Guru Har Rai Intellegent Treasure School, Panjgraian(Tubewell 61 mtr) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.23@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	235	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	0.10@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity	212	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness	184	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
8	Calcium	35.27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	23.32	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	19.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Tempreture condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For,Regional Water Testing Lab  
Amritsar

----- End of the Test Report -----

# REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.

rwtlasr1@gmail.com

## TEST REPORT

Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No 1 Batala SDE Water Supply and Sanitation Sub Division No 1 Batala	Customer Reference No. No : 177 Dated : 15/03/2024
	Sample Submitted by Mr.Gurvinder Singh
	Date of Sample Receipt 18/03/2024
	Analysis Starting Date 19/03/2024
	Analysis completion Date 19/03/2024

Discipline : Chemical Testing	Group: Water
ULR No.:	Sample Type : Water
Test Report No.: RWTLASR/2324/00892	Date of Issue : 20/03/2024
Registration no.: RWTLASR/REG2324/08507	Condition of Sample : Unsealed
Collection Point: Private Submersible	Quantity/Type of Bottle: 500 ml / Amber Colored Glass Bottle
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : Guru Har Rai Intellegent Treasure School, Panjgraian(Tubewell 61 mtr) / NA
Village : Not Mentioned	Habitation : Not Mentioned
Block: Not Mentioned	District : Gurdaspur
Latitude : Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1.	Aluminium	BDL	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium	0.001	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	0.0001	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic	0.001	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium	BDL	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	0.001	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron	BDL	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper	0.01	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	4.953	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS

Note: Detection Limit(Aluminium:0.01, Lead:0.005, Selenium:0.005, Cadmium:0.001, Iron:0.005, )

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For,Regional Water Testing Lab  
Amritsar

End of the Test Report